

CE TEST CERTIFICATE

FOR PERFORMANCE CHARACTERISTICS OF CONSTRUCTION PRODUCTS FOR THE CE MARKING

BOD-19-11-28-01

Product: Wood veneer floor covering with different wood species in the top layer, UV-lacquered
dimensions: length (300-2400) mm x width (50-800) mm x thickness (12-25) mm

Order: Testing of selected properties according to EN 14342:2013 for CE-labelling

Test report: 2708003/160

Test results:

The above mentioned Wood veneer floor covering can be classified regarding to both properties according to EN 14342:2013 (CE-labelling) as follows:

Property	Results	Declaration according to EN 14342:2013
Formaldehyde emission according to EN 717-1:2005	< LOD (264 h)*	class E1
Content of PCP according to CEN/TR 14823:2004	< LOQ**	PCP ≤ 5 x 10 ⁻⁶ n

* LOD = Limit of Detection

** LOQ = Limit of Quantitation

Dresden, 28/11/2019

Head of laboratory



Engineer in charge